



MONTEREY COUNTY REGIONAL FIRE DISTRICT PREVENTION DIVISION

GENERATOR SIGN WORDING

PROJECT NAME: _____

BUILDING PERMIT #: _____

APN: _____

SITE ADDRESS: _____

We have been advised that you are installing an emergency generator at this facility. To assist us with Fire Department Emergency Operations, please reviewed the required wording from the National Electrical Code. The sign must be permanent with 1-inch minimum letters contrasting with the background color. ***Prior to the Fire Department Final*** for this project, this sign (or approved alternate) must be posted and maintained at the following location(s):

- Main Exterior Electrical Shut Off
- Meter
- As follows: _____

**THIS SERVICE CONNECTION IS FED BY A
SECONDARY EMERGENCY GENERATOR
LOCATED AT _____**

(fill in location of system d/c disconnect, inverter and transformer components)

For additional information, please contact:

Monterey County Regional Fire District
(831) 455-1828