

# **SALINAS RURAL FIRE DISTRICT**

---

Steven E. Negro, Fire Chief 19900

Portola

Drive

Salinas, California 93908  
(831) 455-1828 FAX (831) 455-0646

## **FIRE HYDRANT SPECIFICATIONS**

### All Hydrants:

- 0.9 Coefficient
- Brass construction
- Wet barrel
- Hydrant shut-off valve clearance shall be a minimum of 15 feet from hydrant.
- Minimum 18" vertical clearance from center of lowest outlet to finish grade.
- Minimum 36" horizontal clearance from outside of widest outlet (including landscaping).
- If soil retention is an issue, retaining walls shall be added.
- Hydrants shall be pre-flushed prior to fire dept. flushing, flow testing and acceptance.

### Commercial Hydrants:

- Two 2-1/2" Outlets
- One 4-1/2" Outlet

### Residential Hydrants:

- One or Two 2-1/2" Outlet(s)  
(minimum of One 2-1/2" Outlet)
- One 4-1/2" Outlet